



Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

CERTIFICATE

No: 000239/04

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Telefication B.V. certify that the product

3G9080-EU

is in conformity with the following standard(s)

EN 50131-10 June, 2014

Alarm systems - Intrusion and hold-up systems - Part 10: Application specific requirements for Supervised Premises Transceiver (SPT)

EN 50136-2 August, 2013

Alarm systems - Alarm transmission systems and equipment - Part 2: Requirements for Supervised Premises Transceiver (SPT)

Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.

3301 Langstaff Road
L4K 4L2 CONCORD
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

13-10-2026

Signed on behalf of Kiwa FSS products

13 Oct 2022

Ron Scheepers
Managing director



www.certalarm.org

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.



Telefication B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

CERTIFICATE

No: 000239/04 - Annex No 1

Takes into account the following product:

- Product description: Power Series Pro Model 3G9080-EU Cellular Alarm Communicator
- Trademark: DSC/Tyco
- Type designation: 3G9080-EU
- Hardware version: UA716 Rev. 03
- Software version: N/A

Variants:

- Product description: Power Series Pro Model LE9080-EU Cellular Alarm Communicator
- Trademark: DSC/Tyco
- Type designation: LE9080-EU
- Hardware version: UA716 Rev. 06
- Software version: N/A

The optional features of the specifications that are included in the product and test report:

Security grade: 3
Environmental class: II
Equipment class: Fixed
ATS class : SP4 (DP2 or DP3 when combined with LAN or PSTN)

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Factory location:

Tyco International De Mexico S De R.L. De C.V.
Antonio Meucci Yg Gonzalez Camarena 10002
Parque Industrial La Ventana
87569, Matamoros
Mexico

Product inspection location:

AnB Rimex SA
Rue de l'Abbaye 89
4040, Herstal
Belgium

www.certalarm.org

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.



CERTIFICATE

No: 000239/04 - Annex No 1

Test Reports:

- Nemko Canada Inc.: HS3128_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018
- Nemko Canada Inc.: HS3128_HSC3020CP EN50130-4 Report 351713-2TRFEMC, 20 June 2018
- Nemko Canada Inc.: 3G9080-EU_HSC3020C EN50130-4 Report 351717-2TRFEMC, 22 June 2018
- Nemko Canada Inc.: 3G9080-EU_HSC3020CP EN50130-4 Report 351819-2TRFEMC, 28 June 2018
- Telefication: 180600139-001-Ver.2.00, 21 December 2018
- Telefication: 180600139-002-Ver.2.00, 21 December 2018
- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018
- Telefication B.V.: P000118748-003-Ver 1.00, 29 September 2022
- Telefication B.V.: P000118748-ENV-Ver 1.00, 30 September 2022

Applied Standards

EN 50130-5 June, 2011

Alarm systems - Part 5: Environmental test methods

EN 50136-1+A1 November, 2018

Alarm systems - Alarm transmission systems and equipment - Part 1: General requirements for alarm transmission systems

EN 50131-1+A1+A2+A3 June, 2020

Alarm systems - Intrusion and hold-up systems - Part 1: System requirements

EN 50130-4+A1 October, 2014

Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

CERTIFICATE

No: 000239/04 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.