Notified Body No. 0832

BRE Global

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F0515

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FS20X Conventional Class 1 Multi-Spectrum, Multi-Spectral and Multi-Band Infrared and Ultraviolet Fire and Flame Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Honeywell Analytics Inc

405 Barclay Boulevard Lincolnshire Illinois 60069 USA

and produced in the manufacturing plant(s)

Honeywell Analytics Inc

405 Barclay Boulevard Lincolnshire Illinois 60069 USA

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-10:2002 + A1: 2005 Flame Detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 21 August 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Steve Pattrick , Business Group Manager On behalf of BRE Global Limited

Date of issue: 21 August 2015

Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Notified Body No. 0832

BRE Global

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

Appendix to Certificate of constancy of performance 0832-CPR-F0515

Sensitivities:

The very high, high & medium sensitivities meet Class 1 of EN 54-10: 2002 + A1: 2005

Classifications:

Class 1

Ancillary:

SM4 Swivel mount

State of

Steve Pattrick, Business Group Manager

On behalf of BRE Global Limited Date of issue: 21 August 2015

Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.