



# **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

## No. 1293 - CPR - 0538 Rev.2

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable fire alarm manual call point with built-in isolator module SensoIRIS MCP150 IP67, MAGPRO-CPiM IP67, Belinda MCP150 IP67, Erida MCP150 IP67, Marl MCP150 IP67,Smoke sense MCP150 IP67, Expera WP HMi

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

# Teletek Electronics JSC 2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

## Teletek Electronics JSC 2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

# EN 54-11:2001 EN 54-11:2001/A1:2005 EN 54-17:2005 EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

## constancy of performance of the construction product.

This certificate was first issued on September 29<sup>th</sup>, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, September 29th, 2023

Michal M i š i a k

054651

EVPŮ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 1 / 2 FCO 425-13 Rev.1

## Annex to Certificate No. 1293 - CPR - 0538 Rev.2 from September 29th, 2023

### **Technical Specifications**

The addressable manual call point SensoIRIS MCP150 IP67, MAGPRO-CPIM IP67, Belinda MCP150 IP67, Erida MCP150 IP67, Marl MCP150 IP67, Smoke sense MCP150 IP67, Expera WP HMi is designed for outdoor installations and IP67 environments. The call point has a built-in isolator module which when used allows continuous operation of the loop in case of short circuit and without need of using additional isolator modules. The call point is equipped also with a protective transparent cover for avoiding of fault or accidental activation. Call point is powered on from the fire panel and can be controlled via the communication protocol.

#### Products parameters:

Operating voltage: Current consumption without communication (max) Current consumption with communication (max) Current consumption in Fire mode Installation wires Material (plastic), colour Type (according to EN 54-11,17): Type of frangible element Indication "Fire alarm" Operation temperature: Relative humidity Degree of protection: Dimensions: Weight: 15+32VDC 125 μA @ 27 V DC 160 μA @ 27 V DC 3mA 2.5 mm<sup>2</sup> ABS, red A Resettable (flexible) red LED -10°C + +60°C ≤ 93% @ +40°C IP67 114x114x80mm 262q

Essential characteristics	Harmonised technical specification		Performance
	EN 54-11:2001 EN 54-11/A1:2005	EN 54-17:2005 EN 54-17/AC:2007	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	cl. 5.2	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8, 5.9	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11, 5.12, 5.19	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11, 5.13	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5,6, 5,18	cl. 5.3, 5.13	Pass

### History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0538	Original certificate issued	February 8th, 2017
2	1293-CPR-0538 Rev.1	Added new brand name	August 7 <sup>th</sup> , 2017
3	1293-CPR-0538 Rev.2	New location of the company	September 29th, 2023



Michal M i š i a k

Nová Dubnica, September 29th, 2023

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 2 / 2 FCO 425-13 Rev.1