

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00272

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): SmartCell range of wireless control panels
(refer to attached appendix for details and conditions)

Placed on the market
under the name or trade mark of: EMS Limited
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ, United Kingdom

and produced in the
manufacturing plant(s): KGS Manufacturing Poland Sp. Zo.o (SG-25989)
ul Kolejowa 24, 39-100 Ropczyce, Poland

Intended use: Fire Safety
This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012
EN 54-2:1997+A1:2006
EN 54-4:1997+A1:2002+A2:2006

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00272** on **2019-08-16** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body 0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2025-08-26

Issue: 7

Signature:

123277

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00272

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00272

The details and conditions of use for the SmartCell range of wireless control panels, placed on the market under the name or trade mark of:

EMS Limited

Technology House, Sea Street

Herne Bay, Kent, CT6 8JZ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-25:2008+AC:2012, EN 54-2:1997+A1:2006, EN 54-4:1997+A1:2002+A2:2006

Model	Manufacturing Location	Description
SC-11-1201-0000	SG-25989	SmartCell Wireless Control Panel (without communication card) P05353 0G Processor PCB P05354-0F Interface PCB P05205 Enclosure Back box P05206 Enclosure lid moulding P05390 Nordic key drum P05392 Nordic key drum retainer P05369 2 x Sliding cover SC-60-1000 Universal PSU (SmartCell variant) Batteries Lead Acid, 4A/Hr rated

Products compliant with EN54-25:2008+AC:2012, EN54-2:1997+A1:2006

Model	Manufacturing Location	Description
SC-11-2201-0000	SG-25989	SmartCell Wireless Control Panel (24 VDC without communication card) P05353 0G Processor PCB P05354-0F Interface PCB P05205 Enclosure Back box P05206 Enclosure lid moulding P05390 Nordic key drum P05392 Nordic key drum retainer P05369 2 x Sliding cover P05488-01 24V PSU PCB

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00272

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00272

Options with requirements evaluated as being compliant:

Clause 7.8	Output to fire alarm devices
Clause 7.9	Control of fire alarm routing equipment
Clause 7.11	Delays to outputs
Clause 7.12	Dependencies on more than one alarm signal
Clause 8.3	Fault signals from points
Clause 8.9	Output to fault warning routing equipment
Clause 9.5	Disablement of addressable points
Clause 10	Test Condition

Ancillary functions:

The above devices are approved for use with the optional ancillary equipment SC-61-0002 Internal Communication Card which is third party approved to EN 54-21:2006.

Inputs: 2 x Monitored Inputs (Input 1 & 2) programmable 1 x RS232
1 x Ethernet
1 x GSM/GPRS

Outputs: 1 x Volt-free contact fault relay (programmable)
1 x Volt-free contact fire alarm relay (programmable)

Packing variants:

Additional packing code information following the model number: XX-YY-ZZZZ-BBBB-CC

Product Family:	X	Branding	B
Product Line:	X	Branding	B
Group:	Y	Branding	B
Type:	Y	Branding	B
Power:	Z	Country Code	C
Colour:	Z	Country Code	C
Indication:	Z		
Variant:	Z		

The 4-digit branding code relates to packing codes for branded variants. Details are maintained in controlled document - EMS Document BRAND-0001 EMS SmartCell Product Range - Customer Branding Specification.

The 2-digit Country Code relates to packing codes for specific country variants

Conditions of use:

Suitable for indoor applications only.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de


CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00272

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00272

General Notes:

1. Evaluated under Intertek project number 101317801, 101850018, 104114134, G104828711, 104617780 and G106084551
2. SC-60-1000 Universal PSU component of SmartCell CIE was tested with 1x 6V 4Ah Yuasa NP4-6 Lead Acid Battery. Ref Test Report 101317801LHD-004a
3. No CE or other type approval is made or inferred outside of the Assessment and Verification of Constancy of Performance as stipulated on this certificate.



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de