BRE Global

Notified Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Certificate of constancy of performance

0832-CPR-F0990

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

CWS100 Conventional Type A (indoor) Wall Sounder

(For full product details and conditions of use refer to appendix)

Produced by or for

Argus Security Srl

Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy

and produced in the manufacturing plant(s)

Argus Security Srl

Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3: 2001 + A1: 2002 + A2: 2006 Sounders

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 26 October 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 26 October 2015 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Notified Body No. 0832

BRE Global

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Appendix to Certificate of constancy of performance 0832-CPR- F0990

Notes:

1. Meets the requirements of EN 54-3 at the following tone settings:

Tone 1 - Warble Tone 800Hz for 500ms, then 1000Hz for 500ms

Tone 2 - Continuous Tone, 970Hz

Tone 3 – Slow Whoop (Dutch), 500-1200Hz for 3500ms, then off for 500ms

Tone 4 – German DIN Tone, 1200-500Hz swept every 1000ms (1Hz)

Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 26 October 2015 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <u>enquiries@breglobal.com</u>.