



Telefication B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

CERTIFICATE

No: 000198/04

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Telefication B.V. certify that the product

HSM2204

is in conformity with the following standard(s)

EN 50131-6 October, 2017

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.

3301 Langstaff Road
L4K 4L2 CONCORD
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

23-07-2024

Signed on behalf of Kiwa FSS products

23 Jul 2021

Ron Scheepers
Managing director



www.certalarm.org

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.

Page 1 / 4

CERTIFICATE

No: 000198/04 - Annex No 1

Takes into account the following product:

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2204
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.15
- Serial number: N/A

Variants:

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2300
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.14
- Serial number: N/A

The optional features of the specifications that are included in the product and test report:

Security grade: 2
Environmental class: II
Equipment class: Fixed
Power supply type: A

EN compliant when installed in PC5003C or PC5006C enclosure.

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.
ANTONIO MEUCCI YG GONZALEZ CAMARENA # 10002/PARQUE INDUSTRIAL LA VENTANA
87569, Matamoros
Mexico

Product inspection location:

AnB Rimex SA

CERTIFICATE

No: 000198/04 - Annex No 1

Rue de l'Abbaye 89
4040 Herstal
Belgium

Test Reports:

- Telefication B.V.: 20134032800rev2.0, 14 August 2014
- Nemko Canada Inc.: 238276-1TRFEMC, 05 July 2013
- Nemko Canada Inc.: 233462-1TRFEMC, 22 May 2013
- Telefication: 181001649-025-Ver 1.00, 25 March 2019
- Telefication B.V.: 200800715-009-Ver 1.00, 22 March 2021

Applied Standards

EN 50130-5 June, 2011

Alarm systems - Part 5: Environmental test methods

EN 50130-4+A1 October, 2014

Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

EN 50131-1+A1+A2 May, 2017

Alarm systems - Intrusion and hold-up systems - Part 1: System requirements

CERTIFICATE

No: 000198/04 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.