



**EVPU**<sup>®</sup>

NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0866

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR)*, this certificate applies to the construction product

**Expandable Addressable Fire Alarm Control panel  
iRIS4, IRIS 1-4 M, SensoIRIS, MAGPRO9601**

For specifications see Annex No. 1 to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC  
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria**  
and produced in the manufacturing plant

**Teletek Electronics JSC  
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-2: 1997, EN 54-2: 1997/AC: 1999, EN 54-2: 1997/A1: 2006,  
EN 54-4: 1997, EN 54-4: 1997/AC: 1999,  
EN 54-4: 1997/A1: 2002, EN 54-4: 1997/A2: 2006**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on September 25<sup>th</sup>, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, September 25<sup>th</sup>, 2023

Michal Mišiak

054615

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, [www.evpu.sk](http://www.evpu.sk)

Page 1 / 2 FCO 425-13 Rev.1

## Annex No. 1 to Certificate No. 1293 - CPR – 0866 from September 25<sup>th</sup>, 2023

### General informations


iRIS4 (and derivate variants) is an addressable fire alarm control panel for detection, indication, and signalization in case of fire alarm situation in the protected premises. The panel provides coverage of 96 zones and connection of 4 loop expander modules (iRIS8 TTE Loop expander). An arbitrary number of devices can be added to each zone, thus ensuring the easy adaptation of the system to any type of configuration. Panel supports operation with Teletek Electronics communication protocol.

### Technical specifications

Main Power Supply	~230VAC +10% / -15%
Frequency	50/ 60Hz
Backup Battery Power Supply	1 x 12V/ 18Ah or 1 x 12V/17Ah
Dimensions	430x330x120 mm
Weight (without battery)	~6 kg

List of optional functions with requirements included in the c.i.e	
Clause	Description
7.8	Output to the fire alarm device
7.9	Output to fire alarm routing equipment
7.10.3	Output to fire protection equipment – output type C
7.10.4	Fault monitoring of fire protection equipment
7.11	Delay to outputs
7.12.2	Dependencies on more than one alarm signal - type B dependency
7.13	Alarm counter
8.3	Fault signals from points
8.4	Total loss of power supply
8.9	Output to fault warning routing equipment
9.5	Disablement of addressable points
10	Test condition
11	Standardized input/output interface
Supplementary information: <input checked="" type="checkbox"/> - YES, <input type="checkbox"/> - NO	

Essential characteristics	Harmonised technical specification			Performance
	EN 54-2:1997 EN 54-2:1997 /AC:1999 EN 54-2:1997 /A1:2006	EN 54-4:1997 EN 54-4:1997 /AC:1999 EN 54-4:1997 /A1:2002 EN 54-4:1997 /A2:2006		
Performance under fire conditions	cl. 4, 5, 7	---	---	Pass
Performance of power supply	---	cl. 4, 5, 6	---	Pass
Response delay (response time to fire)	cl. 7.1, 7.7, 7.11, 7.12	---	---	Pass
Operational reliability	cl. 4, 5, 6, 7, 8, 9, 10, 11=N/A, 12, 13, 14	cl. 4, 5, 6, 7, 8	---	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 15.4	cl. 9.5	---	Pass
Durability of operational reliability: vibration resistance	cl. 15.6, 15.7, 15.15	cl. 9.7, 9.8, 9.15	---	Pass
Durability of operational reliability: electrical stability	cl. 15.8, 15.9 to 15.12=N/A, 15.13	cl. 9.9, 9.10 to 9.13=N/A	---	Pass
Durability of operational reliability: humidity resistance	cl. 15.5, 15.14	cl. 9.6, 9.14	---	Pass



Nová Dubnica, September 25<sup>th</sup>, 2023

  
Michal Mišiak