

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00427

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): SmartCell range of wireless fire alarm devices, Intelligent Wireless Zone Monitors
(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: EMS Limited
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ, United Kingdom

and produced in the manufacturing plant(s): Carrier Manufacturing Poland Sp. Zo.o. (SG-24159)
ul Kolejowa 24, 39-100 Ropczyce, Poland

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012
EN 54-18:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00427** on **2019-08-16** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body 0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2023-10-09

Issue: 2

Signature:

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00427

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00427

The details and conditions of use for the SmartCell range of wireless fire alarm devices, Intelligent Wireless Zone Monitors, placed on the market under the name or trade mark of:

EMS Limited
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-25:2008+AC:2012, EN54-18:2005+AC:2007

Model	Manufacturing Location	Description
SC-13-1100-0000	SG-24159	Smartcell Intelligent Wireless Zone Monitors (230 VAC)
SC-13-2100-0000	SG-24159	Smartcell Intelligent Wireless Zone Monitors (24 VDC)

Batteries:

Model SC-13-2100-0000 was supplied with power from an external power supply and therefore did not incorporate batteries. Model SC-13-1100-0000 is approved for use with the following batteries:

Manufacturer	Model type
Yuasa (1-off)	NP4-6

Packing variants:

Additional packing code information following the model number:

XX-YY-ZZZZ-BBBB-CC

Product Family: X

Product Line: X

Group: Y

Type: Y

Power: Z

Colour: Z

Indication: Z

Variant: Z

Branding B

Branding B

Branding B

Branding B

Country Code C

Country Code C

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00427

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00427

The 4-digit branding code relates to packing codes for branded variants. Details are maintained in controlled document - EMS Document BRAND-0001 EMS SmartCell Product Range - Customer Branding Specification.

The 2-digit Country Code relates to packing codes for specific country variants.

Conditions of use:

Suitable for indoor applications only

General Notes:

1. Evaluated under Intertek project number 101317801, G104828711
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

