



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0705 Rev.1

In compliance with the *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable fire alarm wall sounder with built-in isolator module SensorIS WS IS, Belinda WS IS, Erida WS IS, Marl WS IS, Smoke sense WS IS, MAGPRO-WSSi, Expera WSBRI

For specifications see Annex to this certificate placed on the market under the name or trade mark of

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006,
EN 54-17:2005, EN 54-17:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, November 6th, 2023

Michal Mišiak

Annex to Certificate No. 1293 - CPR – 0705 Rev.1 from November 6th, 2023

Technical Specifications

SensoIRIS WS IS (derived variants Belinda WS IS, Erida WS IS, Marl WS IS, Smoke sense WS IS, MAGPRO-WSSi, Expera WSBRI) is an addressable Wall Mount Sounder and Strobe designed with built-in isolator module for installing in addressable fire alarm systems supporting TTE communication protocol. The device is powered on from the panel and can be controlled via the communication protocol.

SensoIRIS WS IS, Belinda WS IS, Erida WS IS, Marl WS IS, Smoke sense WS IS, MAGPRO-WSSi are compatible with fire bases B124 for ceiling mounting and WSB IP65 for wall mounting.

Expera WSBRI is compatible with fire bases Expera SB for ceiling mounting and Expera WP SBB for wall mounting.

The device works with Operating voltage (16 – 32) VDC.

| Essential characteristics | Harmonised technical specification | | Performance |
|--|--|--|-------------|
| | EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006 | EN 54-17:2005 EN 54-17:2005/ AC:2007 | |
| Performance under fire conditions | cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1=N/A, C.5.2=N/A, C.5.3=N/A | cl. 5.2 | Pass |
| Operational reliability | cl. 4.4, 4.5, 4.6, 5.4, C4=N/A | cl. 4 | Pass |
| Durability of operational reliability: temperature resistance | cl. 5.5, 5.6, 5.7, 5.8, 5.9 | cl. 5.4, 5.5 | Pass |
| Durability of operational reliability: humidity resistance | cl. 5.8, 5.9, 5.10 | cl. 5.6, 5.7 | Pass |
| Durability of operational reliability: shock and vibration resistance | cl. 5.12 to 5.15 | cl. 5.9 to 5.12 | Pass |
| Durability of operational reliability: corrosion resistance | cl. 5.11 | cl. 5.8 | Pass |
| Durability of operational reliability: electrical stability | cl. 5.16 | cl. 5.3, 5.13 | Pass |
| Durability of operational reliability: resistance to ingress | cl. 5.17 | --- | Pass |

History of certification

| No. | Certificate No. | Description | Date of issue |
|-----|---------------------|-----------------------------|---------------------------------|
| 1 | 1293-CPR-0705 | Original certificate issued | October 28 th , 2020 |
| 2 | 1293-CPR-0705 Rev.1 | New location of the company | November 6 th , 2023 |



Nová Dubnica, November 6th, 2023

Michal Mišiak