



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0461 Rev.3

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable fire alarm sounder and strobe SensolRIS WSST, MAGPRO-WSS23, Belinda WSST, Erida WSST, Marl WSST, Smoke sense WSST

For specifications see Annex No. 1 and No. 2 to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC,

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC, 2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006, EN 54-23:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on July 19th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, July 19th, 2024

Michal M i š i a k Head of CB NB No. 1293

056159

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 1 / 3 F COCV 7.7.12 Rev.1

□ Tiacareń cenin KASICO, a. s., Bratislava, KC24-90985

Annex No. 1 to Certificate No. 1293 - CPR - 0461 Rev.3 from July 19th, 2024

Technical specifications

Product Intelligent analogue addressable fire alarm sounder and strobe SensolRIS WSST,

(Derived variants MAGPRO-WSS23, Belinda WSST, Erida WSST, Marl WSST, Smoke sense WSST) is an addressable Wall mount sounder and strobe designed for installing in addressable fire alarm systems supporting TTE communication protocol.

The device is powered on from the panel and can be controlled via the communication protocol..

The sounder is compatible for mounting on the following bases:

1. SensolRIS B124 - standard low-profile base for addressable detectors and sounders

2. SensoIRIS B124-HP - standard high-profile base for addressable detectors and sounders

3. WSB IP65 - for wall mounting in harsh environmental conditions

Products parameters (Part 1)

Operating Voltage Range

Nominal consumption (stand-by)

Maximal consumption (main tone type 27) - low volume level, sound only

- low volume level, sound and strobe - high volume level, sound only

- high volume level, sound and strobe
Maximal consumption (other tone types)

low volume level, sound only
low volume level, sound and strobe
high volume level, sound only

- high volume level, sound and strobe Power volume (main tone type 27)

low volumehigh volume

Power volume (other tone types)

- low volume - high volume

Tone type specification

Tone type 1 Tone type 2 Tone type 3 Tone type 4

Tone type 5 Tone type 6

Tone type 7
Tone type 8

Tone type 9
Tone type 10

Tone type 10

Tone type 12

Tone type 13

Tone type 14
Tone type 15

Tone type 16

Tone type 17 Tone type 18 Tone type 19

Tone type 20

15 - 32VDC (Nom. 27VDC)

<500µA@27VDC

<5mA <12mA <16.5mA

<22mA

<4mA <11mA <10mA <16.5mA

 \sim 80dB (A) ± 6dB @ 1m \sim 92dB (A) ± 5dB @ 1m

75-85dB ± 3dB @ 1m 80-95dB ± 3dB @ 1m

970 Hz

800Hz/970Hz@2Hz 800Hz - 970Hz@ 1Hz 970Hz 1s OFF/1s ON 970Hz 0,5s / 630 Hz, 0.5 s

554 Hz, 0.1s /440 Hz, 0.4 s (AFNOR NF S 32 001) 500 – 1200 Hz, 3.5s / 0.5s OFF (NEN 2575:2000)

420 Hz 0.625s ON/0.625 OFF (Australia AS1670 Alert tone) 500-1200Hz, 0.5s/0.5s OFF x 3/1.5s OFF (AS 1670 Evacuation)

550 Hz /440 Hz@ 0.5 Hz

970 Hz, 0.5s ON / 0.5s OFFx 3/1.5s OFF (ISO 8201) 2850 Hz, 0.5s ON/ 0.5s OFF x 3/1.5s OFF (ISO8201)

1200 Hz - 500 Hz @ 1 Hz (DIN 33 404)

400 Hz

550 Hz, 0.7 s / 1000 Hz, 0.33 s 1500 Hz - 2700 Hz @ 3 Hz

750 Hz 2400 Hz 660 Hz

660 Hz 1.8 s ON / 1.8 s OFF



Michal M i š i a k Head of CB NB No. 1293

Nová Dubnica, July 19th, 2024

Annex No. 2 to Certificate No. 1293 - CPR - 0461 Rev.3 from July 19th, 2024

Products parameters (Part 2)

Tone type 21 660 Hz 0.15 s ON / 0.15 s OFF Tone type 22 510 Hz 0.25 s / 610 Hz 0.25s Tone type 23 800/1000 Hz 0.5s each (1 Hz) Tone type 24 250 Hz - 1200 Hz @ 12 Hz 500 Hz - 1200 Hz @ 0.33 Hz Tone type 25 Tone type 26 2400 Hz - 2900 Hz @ 9 Hz Tone type 27 2400 Hz - 2900 Hz @ 3 Hz Tone type 28 800 Hz - 970 Hz @ 100 Hz Tone type 29 800 Hz - 970 Hz @ 9 Hz Tone type 30 800 Hz - 970 Hz @ 3 Hz Tone type 31 800 Hz 0.25s ON / 1 s OFF Tone type 32 600 Hz - 1100 Hz, 2.6s / 0.4s OFF Number of tone types 32 Wire Gauge for terminals 2.5mm² Degree of protection IP43C(EN54-3) with base B124 Degree of protection IP 65(EN60529) with base WSB IP65 Operation temperature -10°C ÷ +50°C Relative humidity (93±3)% @ +40°C **Dimensions** 55x116mm Weight 183g Color white Material (transparent) SAN

Essential characteristics	Harmonised technical specification		
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	EN 54-23:2010	Performance
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1=N/A to C.5.3=N/A	cl. 4.3.1 to 4.3.7	Pass
Operational reliability	cl. 4.4 to 4.6, 5.4, C4=N/A	cl. 4.2.1 to 4.2.8	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.5 to 5.9	cl. 4.4.1.1 to 4.4.1.3	Pass
Durability of operational reliability: humidity resistance	cl. 5.8 to 5.10	cl. 4.4.2.1 to 4.4.2.3	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	cl. 4.4.3.1 to 4.4.3.4	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	cl. 4.4.4	Pass
Durability of operational reliability: electrical stability	cl. 5.16	cl. 4.4.5	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17		Pass

W-2.4-6 class

History of certification:

Coverage volume

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0461	Original certificate issued	January 29th, 2015
2	1293-CPR-0461 Rev.1	Change of one brand name	August 14th, 2017
3	1293-CPR-0461 Rev.2	New location of the company	November 6th, 2023
4	1293-CPR-0461 Rev.3	Editorial correction	July 19th, 2024

Nová Dubnica, July 19th, 2024

Michal M i š i a k Head of CB NB No. 1293

056160

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 3 / 3 F COCV 7.7.12 Rev.1

