



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0539 Rev.1

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Conventional fire alarm manual call point SensoMAG MCP50 IP67, SCP2R IP67

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC 2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC 2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001, EN 54-11:2001/A1:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Michal M i š i a k

Nová Dubnica, November 6th, 2023

054842

EVPŮ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 1 / 2 FCO 425-13 Rev.1

Annex to Certificate No. 1293 - CPR - 0539 Rev.1 from November 6th, 2023

Technical Specifications

SensoMAG MCP50 IP67(derived variant SCP2R IP67) is a manual call point, designed for outdoor installations and IP67 endowments.

The call point is equipped also with a protective transparent cover for avoiding of fault or accidental activation.

Products parameters:

Operating voltage: Nominal operating voltage: Current consumption in alarm state Installation wires Relative humidity Material (plastic), colour Type (according to EN 54-11,17): Type of frangible element Indication "Fire alarm" 9+30VDC 24VDC 23mA/15V, 38mA/24V, 48mA/30V 2.5 mm² ≤ 93% @ +40°C ABS, red A Resettable (flexible)

red LED

Essential characteritics	Harmonised technical specifications	Performance	
	EN 54-11:2001 EN 54-11/A1:2005		
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	Pass	
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8=N/A, 5.4, 5.5	Pass	
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8, 5.9	Pass	
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	Pass	
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11, 5.12, 5.19	Pass	
Durability of operational reliability: corrosion resistance	cl. 5.11, 5.13	Pass	
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	Pass	

History of certification

No.	Certificate No.	Description	Date of issue
1.///	1293-CPD-0539	Original certificate issued	February 8th, 2017
2	1293-CPR-0539 Rev.1	New location of the company	November 6th, 2023



Nová Dubnica, November 6th, 2023

Michal M i š i a k

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 2/2 FCO 425-13 Rev.1