

CERTIFICATE

of constancy of performance

1922 - CPR - 2391

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Fire alarm devices – Sounders. Heat detectors - Point heat detectors. Components using radio links.

Heat detector and sounder EN54 FireProtect (Heat/Sounder) Jeweller, model FP.54HA.J-000-EU

Trade mark: AJAX

(with the performance listed, see Annexes I, II and III to 1922-CPR-2391 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of

AJAX SYSTEMS CYPRUS HOLDINGS LTD

Ifigeneias, 17, Strovolos, 2007, Nicosia, Cyprus

and produced in the manufacturing plant

001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-3:2001; EN 54-3:2001/A1:2002; EN 54-3:2001/A2:2006;

EN 54-5:2017+A1:2018; EN 54-25:2008; EN 54-25:2008/AC:2012

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 27.05.2025 and will remain valid until 05.10.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Attestation & Certification

Manager:

Anna Vasileva



dipl. eng. Anna Vasileva

Issued:
Burgas, 25 June 2025

Ref. No. 02-00

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-2391/ 25.06.2025

Performance list, acc. to EN 54-3:2001; EN 54-3:2001/A1:2002; EN 54-3:2001/A2:2006;

| Essential Characteristics | Performance | Clause |
|--|-------------|--------|
| Performance parameters under fire conditions | | |
| - Sound level | Pass | 4.2 |
| - Frequencies and sound pattern | Pass | 4.3 |
| - Reproducibility | Pass | 5.2 |
| - Operational performance | Pass | 5.3 |
| - Attention drawing signal and message broadcast sequences | N/A | C.3.1 |
| - Synchronisation | N/A | C.3.2 |
| - Broadcast message performance | N/A | C.5.1 |
| - Attention drawing signal/silence/message sequence timing | N/A | C.5.2 |
| - Message synchronization testing | N/A | C.5.3 |
| Operational reliability | | |
| - Durability | Pass | 4.4 |
| - Construction | Pass | 4.5 |
| - Marking and data | Pass | 4.6 |
| - Durability | Pass | 5.4 |
| - General testing | N/A | C.4 |
| Durability of operational reliability, temperature resistance | | |
| - Dry heat (operational) | Pass | 5.5 |
| - Dry heat (endurance) | N/A | 5.6 |
| - Cold (operational) | Pass | 5.7 |
| - Damp heat, cyclic (operational) | Pass | 5.8 |
| - Damp heat, steady state (endurance) | Pass | 5.9 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, cyclic (operational) | Pass | 5.8 |
| - Damp heat, steady state (endurance) | Pass | 5.9 |
| - Damp heat, cyclic (endurance) | N/A | 5.10 |
| Durability of operational reliability, corrosion resistance | | |
| - Sulphur dioxide (SO ₂) corrosion (endurance) | Pass | 5.11 |
| Durability of operational reliability, shock and vibration resistance | | |
| - Shock (operational) | Pass | 5.12 |
| - Impact (operational) | Pass | 5.13 |
| - Vibration, sinusoidal (operational) | Pass | 5.14 |
| - Vibration, sinusoidal (endurance) | Pass | 5.15 |
| Durability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity (operational) | Pass | 5.16 |
| Durability of operational reliability, resistance to ingress | | |
| - Enclosure protection | Pass | 5.17 |



Manager:

Anna Vasileva



dipl. eng. Anna Vasileva

Issued:
Burgas, 25 June 2025

Ref. No. 02-00

ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-2391/ 25.06.2025

Performance list, acc. to EN 54-5:2017+A1:2018

| Essential Characteristics | Performance | Clause |
|--|-------------|---------|
| Operational reliability | | |
| - Position of heat sensitive element | Pass | 4.2.1 |
| - Individual alarm indication | Pass | 4.2.2 |
| - Connection of ancillary devices | N/A | 4.2.3 |
| - Monitoring of detachable point heat detectors | Pass | 4.2.4 |
| - Manufacturing adjustments | Pass | 4.2.5 |
| - On site adjustment of response behaviour | Pass | 4.2.6 |
| - Software controlled detectors (when provided) | Pass | 4.2.7 |
| Nominal activation conditions/ Sensitivity | | |
| - Directional dependence | Pass | 4.3.1 |
| - Static response temperature | Pass | 4.3.2 |
| - Response times from typical application temperature | Pass | 4.3.3 |
| - Response times from 25 °C | Pass | 4.3.4 |
| - Response times from high ambient temperature | Pass | 4.3.5 |
| - Reproducibility | Pass | 4.3.6 |
| Response delay (response time) | | |
| - Additional test for suffix S point heat detectors | Pass | 4.4.1 |
| - Additional test for suffix R point heat detectors | Pass | 4.4.2 |
| Tolerance to supply voltage | | |
| - Variation in supply parameters | Pass | 4.5 |
| Durability of Nominal activation conditions /Sensitivity | | |
| Temperature resistance | | |
| - Cold (operational) | Pass | 4.6.1.1 |
| - Dry heat (endurance) | Pass | 4.6.1.2 |
| Humidity resistance | | |
| - Damp heat, cycling (operational) | Pass | 4.6.2.1 |
| - Damp heat, steady-state (endurance) | Pass | 4.6.2.2 |
| Corrosion resistance | | |
| - Sulphur dioxide (SO ₂) corrosion (endurance) | Pass | 4.6.3 |
| Vibration Resistance | | |
| - Shock (operational) | Pass | 4.6.4.1 |
| - Impact (operational) | Pass | 4.6.4.2 |
| - Vibration, sinusoidal (operational) | Pass | 4.6.4.3 |
| - Vibration, sinusoidal (endurance) | Pass | 4.6.4.4 |
| Durability of operational reliability, electrical stability | | |
| - (EMC), immunity (operational) | Pass | 4.6.5 |



Attestation & Certification

Manager:

Anna Vasileva



dipl. eng. Anna Vasileva

Issued:
Burgas, 25 June 2025

Ref. No. 02-00

ANNEX III TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-2391/ 25.06.2025

Performance list, acc. to EN 54-25:2008; EN 54-25:2008/AC:2012

| Essential Characteristics | Performance | Clause |
|---|-------------|--------|
| Performance under fire conditions | | |
| - General | Pass | 4.1 |
| - Alarm signal integrity | Pass | 4.2.2 |
| - General | Pass | 5.2 |
| - Reproducibility test | Pass | 8.3.7 |
| Response delay (response time to fire) | | |
| - Test for alarm signal integrity | Pass | 8.2.3 |
| - Test for mutual disturbance between systems of the same manufacturer | Pass | 8.2.6 |
| Operational reliability | | |
| - Immunity to site attenuation | Pass | 4.2.1 |
| - Identification of the RF linked component | Pass | 4.2.3 |
| - Receiver performance | Pass | 4.2.4 |
| - Immunity to interference | Pass | 4.2.5 |
| - Loss of communication | Pass | 4.2.6 |
| - Antenna | Pass | 4.2.7 |
| - Power supply equipment | Pass | 5.3 |
| - Environmental related requirements | Pass | 5.4 |
| - Documentation | Pass | 6 |
| - Marking | Pass | 7 |
| - Test for immunity to site attenuation | Pass | 8.2.2 |
| - Test for identification of RF linked components | Pass | 8.2.4 |
| - Test for identification of RF linked components | Pass | 8.2.5 |
| - Test of compatibility with other band users | Pass | 8.2.7 |
| - Test for the detection of a loss of communication on a link | Pass | 8.2.8 |
| - Test of the antenna | Pass | 8.2.9 |
| - General | Pass | 8.3.1 |
| - Test schedule for components tests | Pass | 8.3.2 |
| - Verification of the service life of the autonomous power source(s) | Pass | 8.3.3 |
| - Test for the low power condition fault signal | Pass | 8.3.4 |
| - Test for the polarity reversal | N/A | 8.3.5 |
| - Repeatability test | Pass | 8.3.6 |
| Durability of operational reliability and response delay, temperature resistance | | |
| - Dry heat (operational) | Pass | 8.3.9 |
| - Dry heat (endurance) | Pass | 8.3.10 |
| - Cold (operational) | Pass | 8.3.11 |
| Durability of operational reliability, vibration resistance | | |
| - Shock (operational) | Pass | 8.3.16 |
| - Impact (operational) | Pass | 8.3.17 |
| - Vibration, sinusoidal (operational) | Pass | 8.3.18 |
| - Vibration, sinusoidal (endurance) | Pass | 8.3.19 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, cyclic (operational) | Pass | 8.3.12 |
| - Damp heat, steady state (operational) | N/A | 8.3.13 |
| - Damp heat, steady state (endurance) | Pass | 8.3.14 |
| Durability of operational reliability, corrosion resistance | | |
| - SO2 corrosion (endurance) | Pass | 8.3.15 |
| Durability of operational reliability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | Pass | 8.3.20 |



Attestation & Certification

Manager:

Anna Vasileva



dipl. eng. Anna Vasileva

Issued:
Burgas, 25 June 2025

Ref. No. 02-00