



Certificate of Conformity

Product Certification Scheme 5

Certificate No. 31810-01-25-INT

This certificate applies to the products

Warning devices

with name and/or type designation

AS610, AS619, AS630

Placed on the market by

KGS Fire & Security B.V

Kelvinstraat 7, 6003 DH Weert, Netherlands

Produced in the manufacturing plant by

5 Win Technology Inc,

No 7, Kai Fa 4rd, Pao An Industrial Area, Ren De District, Taiwan

This certificate attests that all provisions concerning the assessment and the performance described in the standard

EN 50131-4:2019

are applied and that the products fulfils all the prescribed requirements

This Certificate is valid until 2029-06-25

Høvik, Norway 2025-06-25

For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen, Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2025-06-25

Products Covered by this Certificate		
Product Name	Product Description	Applied Standards
AS610	Warning devices Outdoor sirens	EN 50131-4:2019
AS619		EN 50130-4:2011/A1:2014
AS630		EN 50130-5:2011

Products Specifications		
Product Name	Environmental Class/Security Grade	Sound Level
AS610	III/3	-
AS619	III/3	The sound level of AS619 is lower than the specifications in EN 50131-4. According to the manufacturer, this product has been designed to meet the national requirements for the sound level in Spain. Ref EN50131-4, Item 5.1.2, Note 4.
AS630	III/3	-

Documents Reviewed	
Document ID	Description
20325 rev 01	EN 50131-1:2006+A1:2009 EN 50131-4:2009 EN 50130-4:2011
2010-3566 rev 01	EN 50131-1:2006+A1:2009, EN 50131-4:2009 EN 50130-5:1998
Technical Report 30708 rev 1	EN 50130-4:2011/A1:2014 EN 50130-5:2011 (Shock)
Test report P901540E	EN 50130-5:1998

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plant
- Changes in the test methods and/or factory production control requirements included in the standard(s), used to assess the performance of the declared characteristics

END OF CERTIFICATE