

CERTIFICATE

No: 000221/04

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we
Telefication B.V. certify that the product

HS2TCHP

is in conformity with the following standard(s)

EN 50131-3 March, 2009

Alarm systems - Intrusion and hold-up systems - Part 3: Control and indicating equipment

Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.
3301 Langstaff Road
L4K 4L2 CONCORD
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.
This certificate is valid until:
14 August 2024

Zevenaar, 14 August 2020

Signed on behalf of Telefication B.V.



Marcellino Jansen
Test Engineer



CERTIFICATE

No: 000221/04 - Annex No 1

Takes into account the following product and variants:

- Product description: I&HAS Keypad
- Trademark: DSC/Tyco
- Type designation: HS2TCHP
- Hardware version: UA664 Rev. 02
- Software version: 1.3
- Serial number: N/A

- Product description: I&HAS Keypad
- Trademark: DSC/Tyco
- Type designation: HS2TCHPRO
- Hardware version: UA664 Rev. 02
- Software version: 2.1
- Serial number: N/A

- Product description: I&HAS Keypad
- Trademark: DSC/Tyco
- Type designation: HS2TCHPROBLK
- Hardware version: UA664 Rev. 02
- Software version: 2.1
- Serial number: N/A

The optional features of the specifications that are included in the product and test report:

Security grade: 3
Environmental class: II
Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Factory location:
TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.
ANTONIO MEUCCI YG GONZALEZ CAMARENA # 10002/PARQUE INDUSTRIAL LA VENTANA
87569, Matamoros
Mexico

Storage location:
AnB Rimex SA
Rue de l'Abbaye 89
4040 Herstal
Belgium

CERTIFICATE

No: 000221/04 - Annex No 1

Applied Standards

EN 50130-5 June, 2011

Alarm systems - Part 5: Environmental test methods

EN 50130-4+A1 October, 2014

Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

EN 50131-1+A1+A2 May, 2017

Alarm systems - Intrusion and hold-up systems - Part 1: System requirements

Test Reports:

- Telefication B.V.: 160201681-001-Ver 1.00, 22 June 2016
- Nemko Canada Inc.: HSTTCHP (UA664 Rev 02) EN50130-4 Nemko Report 270085-2TRFEMC, 17 December 2014
- Telefication B.V.: 180600139-001-Ver.3.00, 18 April 2019

CERTIFICATE

No: 000221/04 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.