

CERTIFICATE

No: 000237/03

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we
Telefication B.V. certify that the product

HS3128

is in conformity with the following standard(s)

EN 50131-10 June, 2014

Alarm systems - Intrusion and hold-up systems - Part 10: Application specific requirements for Supervised Premises Transceiver (SPT)

EN 50131-3 March, 2009

Alarm systems - Intrusion and hold-up systems - Part 3: Control and indicating equipment

EN 50131-6 October, 2017

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

EN 50136-2 August, 2013

Alarm systems - Alarm transmission systems and equipment - Part 2: Requirements for Supervised Premises Transceiver (SPT)

Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.

3301 Langstaff Road

L4K 4L2 CONCORD

Canada

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

04 December 2022

Zevenaar, 08 November 2019

Signed on behalf of Telefication B.V.



Jan Willem Verwoert
Project Manager



CERTIFICATE

No: 000237/03 - Annex No 1

Takes into account the following product and variants:

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3128
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3128P
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3032
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3032P
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3248
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3248P
- Hardware version: UA718 Rev. 03
- Software version: 1.1
- Serial number: N/A

The optional features of the specifications that are included in the product and test report:

The Model HS3032, HS3128 and HS3248 Control Panel is compliant to EN 50131-3:2009 Type B,

www.certalarm.org

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.



CERTIFICATE

No: 000237/03 - Annex No 1

EN 50131-6:2017 Type A, EN 50131-10, EN 50136-2:2013 ATS SP3 (dialer), SP4 (Ethernet), DP2 (dialer and Ethernet), DP3 (Ethernet and plug-in

cellular) when installed in enclosure models HSC3020C or HSC3020CP.

When HS3032, HS3128 or HS3248 Control panel is mounted in the plastic enclosure model HSC3020CP the final product model name is HS3032P, HS3128P or HS3248P.

Security grade: 3

Security grade: 2: When HSM2HOST8 is added to HS3032, HS3128 or HS3248 (either external use in its own plastic enclosure or mounted in the control panel plastic enclosure HSC3020CP)

Environmental class: II

Equipment class: Fixed

Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2 (when HSM2HOST8 is added to HS3032, HS3128 or HS3248 (either external use in its own plastic enclosure or mounted in the control panel plastic enclosure HSC3020CP) or grade 3.

Electromagnetic emission and safety aspects are not covered by this certificate.

Applied standards:

EN 50131-1:2006 + A1:2009 + A2:2017

EN 50136-1:2012 + A1:2018

EN 50130-4:2001 + A1:2014

EN 50130-5:2011

Factory location:

Tyco International De Mexico S De R.L. De C.V.

Antonio Meucci Yg Gonzalez Camarena 10002

Parque Industrial La Ventana

87569, Matamoros

Mexico

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040, Herstal

Belgium

Test Reports:

- Nemko Canada Inc.: HS3128_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018

- Nemko Canada Inc.: HS3128_HSC3020CP EN50130-4 Report 351713-2TRFEMC, 20 June 2018

- Telefication: 180600139-002-Ver.2.00, 21 December 2018

- Telefication: 180600139-003-Ver 1.00, 04 December 2018

- Telefication: 180600139-001-Ver.3.00, 18 April 2019

- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018

CERTIFICATE

No: 000237/03 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.