



EU DECLARATION OF CONFORMITY

for

Product identification

Model Type	NC-PF4	Conventional fire panel, 4 zone
	NC-PF4-SC	Conventional Fire Panel with Scandinavian Key - 4 Zone
Category (description)	Fire detection and fire alarm systems: <ul style="list-style-type: none">• Control and indicating equipment• Power supply equipment	
Brand	Kidde Commercial	

Name and address of the Manufacturer

Carrier Manufacturing Poland Spółka Z o. o. ul. Kolejowa 24, 39 - 100 Ropczyce, Poland

EU Representative

Carrier Fire & Security B.V. Kelvinstraat 7 NL-6003 DH Weert, The Netherlands

This declaration of conformity is issued under the sole responsibility of the manufacturer.

References to the relevant harmonized standards used in relation to which conformity is declared

Concerning	EMC 2014/30/EU	LVD 2014/35/EU	CPR 305/2011
A sample of the product has been tested by	LGAi Technological Center, S.A. Campus UAB, Apdo. Correos 18, 08193 Bellaterra, Barcelona, Spain Carrier Fire & Security España, S.L. Verge de Guadalupe 3, 08950 Esplugues de Llobregat, Barcelona, Spain	LGAi Technological Center, S.A. Campus UAB, Apdo. Correos 18, 08193 Bellaterra, Barcelona, Spain	LGAi Technological Center, S.A. Campus UAB, Apdo. Correos 18, 08193 Bellaterra, Barcelona, Spain (Notified Body under registration number 0370)
Applied standards	EN 50130-4:2011 + A1:2014 EN 55032:2015 + A11:2020 EN IEC 61000-3-2:2019 EN 61000-3-3:2013 + A1:2019	EN 62368-1:2014 + AC:2015 + AC:2015 + AC:2015 + AC:2017-03 + A11:2017	EN 54-2:1997 + AC:1999 + A1:2006 EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006

Year of affixing the CE marking

2024

Means of conformity


We declare under our sole responsibility that this product is in conformity with Directive 2014/30/EU (EMC), 2014/35/EU (LVD) and 93/68/EEC (Marking), based on test results using harmonized standards in accordance with the Directives mentioned and with the Regulation EU n° 305/2011 based on the certification by the Notified Body mentioned.

Environmental Directives

We also declare under our sole responsibility that this product is in conformity with following Environmental Directives 2015/863/EU amending RoHS Directive 2011/65/EU and Directive 2012/19/EU (WEEE).

With the following accessories:

Product	Product description
1X-F4-MB	Conventional Fire Panel - PCB - 4 Zone
2010-1-RB	Conventional Fire Panel Accessory - Relay Printed Circuit Board - Unsupervised
2010-1-SB	Conventional Fire Panel Accessory - Relay Printed Circuit Board - Supervised
2010-1-NB	Conventional Fire Panel Accessory - Network Interface
2010-PS-20	Fire Panel Component - Power Supply Unit - 2A
2010-1-AC	Conventional Fire Panel Component - Alarm Counter
2010-SK	Fire Panel - Keys & Lock - Scandinavia

Signed for and on behalf of the manufacturer by: Name: José María Méndez Seguí Function: Technology Manager, EMEA Place: Verge de Guadalupe 3, 08950 Esplugues de Llobregat, Barcelona, Spain At: Esplugues de Llobregat	 Date of issue: July 19, 2024
--	---