Declaration of Performance No. 0359-CPR-00272 REV 06

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011 and UKCA requirements

Model(s): SC-11-1200, SC-11-2200, SC-11-1201, SC-11-2201 and SC-61-0002 communication card (separate EN 54-21
approved) Brand(s): SmartCell
Each individual product is identified with a label containing a unique serial number.
Fire detection and fire alarm systems – Control & Indicating Equipment - EN54-2
Fire detection and fire alarm systems – Power Supplies - EN54-4
Fire detection and fire alarm systems – Components using radio links EN54-25
KGS Manufacturing Poland Spółka Z o. o.
ul. Kolejowa 24 39-100 Ropczyce, POLAND
EMS Limited
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ.
System 1
Intertek Deutschland GmbH– 0905; performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued an EC certificate of conformity. 0905-CPR-00272
Intertek UK – 0359 performed type testing and intial initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued an EC certificate of conformity.
Not applicable, see point 7

Declared performance: All requirements including all Essential Characteristics and the corresponding performances for the intended use
or uses indicated in point 3 above have been determined as described in the harmonised technical specifications: EN54-18:2005 and EN
54-25: 2008 mentioned in the table(s) below.

Fire detection and fire alarm systems - Control & Indicating Equipment - EN54-2

Essential characteristics	Performance	Requirement clauses in this European standard
Performance under fire conditions	PASS	4, 5, 7 (notes a,b)
Response delay (response time)	PASS	7.1, 7.7, 7.11, 7.12 (note a)
Operational reliability	PASS	4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14 (note a)
Durability of operational reliability,	PASS	15.4
Temperature resistance		
Durability of operational reliability,	PASS	15.6, 15.7, 15.15
Vibration resistance		
Durability of operational reliability,	PASS	15.8 to 15.13
Electrical resistance		
Durability of operational reliability,	PASS	15.5, 15.14
Humidity stability		

a) For compliance with this standard it is not necessary to provide the optional functions specified in the standard. However, if a manufacturer chooses to include any of these options in the equipment, then the associated requirements shall be met and have to be included in type testing and certification (see Clause 4 of this standard).

b) The products covered by this standard are assumed to function during the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

Fire detection and fire alarm systems - Power Supplies - EN54-4

Essential characteristics	Performance	Requirement clauses in this European standard
Performance of power supply	PASS	4, 5, 6 (notes a)
Operational reliability	PASS	4, 5, 6, 7, 8 (note a)
Durability of operational reliability,	PASS	9.5
Temperature resistance		
Durability of operational reliability,	PASS	9.7, 9.8, 9.15
Vibration resistance		
Durability of operational reliability,	PASS	9.9 to 9.13
Electrical resistance		
Durability of operational reliability,	PASS	9.6, 9.14
Humidity stability		ing the alarm condition, in an event of fire, before the fire

becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from

Fire detection and fire alarm systems - Components using radio links EN54-25

Essential characteristics	Performance	Requirement clauses in this European standard
Performance parameters under fire	PASS	4.1, 4.2.2, 5.2, 8.3.7 (see note a)
conditions		
Response delay (response time to fire)	PASS	8.2.3, 8.2.6 (see note a)
Operational reliability	PASS	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8 ^b , 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.5, 8.3.6
Durability of operational reliability,	PASS	8.3.9°, 8.3.10°, 8.3.11
Temperature resistance		
Durability of operational reliability,	PASS	8.3.16 ^c , 8.3.17 to 8.3.19
Vibration resistance		
Durability of operational reliability,	PASS	8.3.12 ^d , 8.3.13 ^e , 8.3.14
Humidity resistance		
Durability of operational reliability,	PASS	8.3.15 ^c
Corrosion resistance		
Durability of operational reliability,	PASS	8.3.20
Electrical stability		

- a The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is no requirement to function when exposed to direct attack from fire.
- b Only applicable to components required to indicate loss of communication or to transmit this information to the CIE.
- c Not applicable for CIE.
- d Not applicable for CIE and smoke detectors.
- e Only applicable for CIE and smoke detectors.
- 10. The performance of the product identified in items 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed by: Daniel Griffin

Director of Product & Compliance

Location: EMS Limited, Date: 26th March 2025

Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ, U.K.

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information



Identification of the Certification Body: 0905

Manufacturer: KGS Manufacturing Poland Spółka Z o. o, ul. Kolejowa 24, 39-100 Ropczyce, POLAND

Last two digits of year CE mark was first placed: 19

Declaration of Performance (DoP) Number: 0359-CPR-00272 REV 06

EN54-2:1997+A1:2006, EN 54-4:1998+A1,A2, and EN 54-25:2008

Unique identification of product type: See the product label for the product documentation part number and $\frac{1}{2}$

revision.

Intended use: See DoP point 3.

Essential characteristics: See DoP point 9.

UKCA marking information



Identification of the Certification Body: 0359

Manufacturer: KGS Manufacturing Poland Spółka Z o. o, ul. Kolejowa 24, 39-100 Ropczyce, POLAND

Last two digits of year UKCA mark was first placed: 25

Declaration of Performance (DoP) Number: 0359-CPR-00272 REV 06

EN54-2:1997+A1:2006, EN 54-4:1998+A1,A2, and EN 54-25:2008

Unique identification of product type: See the product label for the product documentation part number and

revision.

Intended use: See DoP point 3.

Essential characteristics: See DoP point 9.