



EVPÚ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0554 Rev.1

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Conventional sounder with strobe
SF100 WSST, Hera WSST, Aura WSST, Tera WSST**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 54-3: 2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006,
EN 54-23: 2010**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, November 6th, 2023


Michal Mišiak

054830

Annex to Certificate No. 1293 - CPR – 0554 Rev.1 from November 6th, 2023

General Information:

SF 100WSST is a conventional fire alarm sounder with a strobe. The sounder supports 32 different alarm tone types selectable via DIP switches on the PCB.

Technical specifications:


Operating Voltage Range: 20-28VDC
 Maximal consumption (main tone type 27):
 - low volume level, without strobe: 8.5 mA @ 24VDC
 - low volume level, with strobe: 12 mA @ 24VDC
 - high volume level, without strobe: 22mA @ 24VDC
 - high volume level, with strobe: 25mA @ 24VDC
 Sound volume (main tone type 27):
 - low volume: 87-96dB @ 1m
 - high volume: 95-104dB @ 1m
 Sound volume (other tone types):
 - low volume: 82-98dB @ 1m
 - high volume: 85-104dB @ 1m
 Number of tone types: 32
 Operating temperature: -10°C to +60°C
 Relative humidity resistance: (93±3)% @ +40°C
 IP Protection: IP21C
 Weight: ~248g
 Dimensions: 102x32mm

Essential characteristics	Harmonised technical specification		Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	EN 54-23:2010	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	cl. 4.3.1 to 4.3.6, 4.3.7=N/A	Pass
Operational reliability	cl. 4.4, 4.5, 4.6, 5.4, C.4=N/A	cl. 4.2.1 to 4.2.8	Pass
Durability of operational reliability: temperature resistance	cl. 5.5, 5.6=N/A, 5.7, 5.8, 5.9	cl. 4.4.1.1, 4.4.1.2=N/A, 4.4.1.3	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10=N/A	cl. 4.4.2.1, 4.4.2.2, 4.4.2.3=N/A	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	cl. 4.4.3.1 to 4.4.3.4	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	cl. 4.4.4	Pass
Durability of operational reliability: electrical stability	cl. 5.16	cl. 4.4.5	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	—	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0554	Original certificate issued	May 9 th , 2017
2	1293-CPR-0554 Rev.1	New location of the company	November 6 th , 2023

Nová Dubnica, November 6th, 2023




 Michal Mišiak