



Certificate of Conformity

Product Certification Scheme 5

Certificate No. P21239-01-17-INT

This certificate applies to the product(s)

SPT Type Z integrated in control panel

with name and/or type designation

XL200 and XL200L

Placed on the market by

RSI Video Technologies

25, rue Jacobi-Netter, 67200 Strasbourg, France

Produced in the manufacturing plant by

AsteelFlash France Etablissement Est

9 rue Ampère, 67120 Duttlenheim, France

Cordan CMS

ZA de Muehlbach, BP 80075, 68153 Ribeauville Cedex, France

This certificate attests that all provisions concerning the assessment and the performance described in the standard(s)

EN 50131-10:2014 in conjunction with

EN 50136-1:2012

EN 50136-2:2013

are applied and that the product(s) fulfil(s) all the prescribed requirements

This Certificate is valid until 2021-11-21

Høvik, Norway 2017-11-21

For Applica Test & Certification AS

A handwritten signature in blue ink that reads 'Vibeke Vigmøstad'.

Vibeke Vigmøstad, Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2017-11-21

Product(s) Covered by this Certificate		
Product Name	Product Description	Applied Standards
XL200	SPT Type Z integrated in control panel	EN 50131-10:2014 in conjunction with
XL200L	SPT Type Z integrated in control panel	EN 50136-1:2012 EN 50136-2:2013

Product(s) Specifications		
Product Name	ATS Configuration	ATS Classification
	EN 50131-10:2014	EN 50136-1:2012
XL200 XL200L	Type Z	SP 2

Application/Limitation

- Security Grade 2
- Environmental Class II

Document(s) Reviewed	
Document ID	Description
21175 Rev. 2	Test report according to: EN 50131-10:2014, EN 50136-1:2012 and EN 50136-2:2013
17 00 37	Test reports according to: EN 50130-4:2011/A1:2014
17 00 38	
17 00 45	
17 00 46	Test reports according to: EN 50130-5:2011
100415425MIN-002	Test report according to: EN 50130-5:2011, Clause 20

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the product(s) listed above
- The product(s) is(are) to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The product(s) listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the product(s)
- Significant changes in the manufacturing plan(s)
- Changes in the test methods and/or factory production control requirements included in the standard(s), used to assess the performance of the declared characteristics

END OF CERTIFICATE